



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18010-75-1590
State Number
30520

EQUIPMENT INSPECTED

| | | |
|----------------------------|----------------------------|------------------------|
| State Number: 30520 | Type of Unit: Passenger | Floor to Floor: 1 to 2 |
| Capacity: 2500 | Manuf: OTIS | Speed: 125 |
| Landings: 2 | Installed: 10/05/2016 | Rope Size: |
| Volts: 480 | Complied: 10/05/2016 | Entrances: 1 |
| OWNER | OCCUPANT | |
| ALTAMONT INVESTMENTS LLC | AVL TECHNOLOGIES EXPANSION | |
| 16 N MERRIMON AVENUE | 16 N MERRIMON AVENUE | |
| WOODFIN, NC, 28804 | WOODFIN, NC, 28804 | |

INSPECTION INFORMATION

| | | | | | |
|-------------------------------|----------------------------|---------------------------------|---------------------------|--------------------|------|
| Inspection Date 01/10/2018 | Type Inspection Routine | Certificate Status Re-issued | Inspector 75 - Edwards | County BUNCOMBE | 11 A |
|-------------------------------|----------------------------|---------------------------------|---------------------------|--------------------|------|

VIOLATIONS

8.6.1.4.1(d) Document a written record of the fire fighter's service operation.

Items must be corrected by: 03/11/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Guary Burnette 828-772-5918

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALTAMONT INVESTMENTS LLC
16 N MERRIMON AVENUE
WOODFIN, NC, 28804