



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18011-75-4847
State Number
30671

EQUIPMENT INSPECTED

State Number: 30671	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: VERT EXP	Speed: 150
Landings: 3	Installed: 10/06/2016	Rope Size:
Volts: 480	Complied: 10/06/2016	Entrances: 1

OWNER

ASHEVILLE ART MUSEUM
2 S PACK SQUARE
ASHEVILLE, NC, 28801

OCCUPANT

DIANA WORTHAM THEATRE
2 S PACK SQUARE
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 01/11/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

2.27.1.1.1	Place the in-car Emergency Phone in working order.
8.6.5.7	Provide an oil usage log in the machine room.
8.6.5.14.1	Provide the annual relief valve and hydraulic system pressure test.

Items must be corrected by: 03/12/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeanette Houston 828-275-3276

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE ART MUSEUM
2 S PACK SQUARE
ASHEVILLE, NC, 28801