



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18023-65-2594
State Number
21596

EQUIPMENT INSPECTED

State Number: 21596	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: ASHEVILLE	Speed: 95
Landings: 2	Installed: 08/14/2003	Rope Size: 0
Volts: 480	Complied: 08/14/2003	Entrances: 1

OWNER

ASHEVILLE CHRISTIAN ACADEMY
PO BOX 1089
SWANNANOVA, NC, 28778

OCCUPANT

ASHEVILLE CHRISTIAN ACADEMY
74 RIVERWOOD ROAD
SWANNANOVA, NC, 28778

INSPECTION INFORMATION

Inspection Date 01/23/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------	------

VIOLATIONS

Elevator Name: ELEVATOR WEST

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Mark Brant 828-545-8234

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE CHRISTIAN ACADEMY
PO BOX 1089
SWANNANOVA, NC, 28778