



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18023-65-2688**  
State Number  
**29485**

#### EQUIPMENT INSPECTED

State Number: <b>29485</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: VERT EXP	Speed: 95
Landings: 2	Installed: 08/13/2014	Rope Size:
Volts: 460	Complied:	Entrances: 1
OWNER	OCCUPANT	
ASHEVILLE CHRISTIAN ACADEMY	ASHEVILLE CHRISTIAN ACADEMY STUDENT CTR	
74 RIVERWOOD	74 RIVERWOOD	
SWANNANOVA, NC, 28778	SWANNANOVA, NC, 28778	

#### INSPECTION INFORMATION

Inspection Date 01/23/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------	------

#### VIOLATIONS

8.6.4.7	Clean the pit and the pit equipment.
8.6.4.7	Remove the water from the pit floor and take steps to prevent its re-entry.

Items must be corrected by: 03/24/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Mark Brant 828-545-8234

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE CHRISTIAN ACADEMY  
74 RIVERWOOD  
SWANNANOVA, NC, 28778