



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18024-54-4024**  
State Number  
**1592**

EQUIPMENT INSPECTED

State Number: <b>1592</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4000	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 01/18/1952	Rope Size: 1/2
Volts: 208	Complied: 01/18/1952	Entrances: 1
OWNER	OCCUPANT	
LANDMARK PROPERTY MGMT	CASHIE APARTMENTS FOR THE ELDERLY	
FOR CASHIE APTS	401 STERLINGWORTH DR	
WINSTON SALEM, NC, 27101	WINDSOR, NC, 27983	

INSPECTION INFORMATION

Inspection Date 01/24/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 54 - Green	County BERTIE
-------------------------------	----------------------------	---------------------------------	-------------------------	------------------

8

VIOLATIONS

8.6.4.7 Remove the water from the pit floor and take steps to prevent its re-entry.

Items must be corrected by: 02/23/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ASHLEY HORROCKS 252 794 2974

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LANDMARK PROPERTY MGMT  
FOR CASHIE APTS  
WINSTON SALEM, NC, 27101