

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-807-2770

Report Number 18029-73-1832 State Number 29884

EQUIPMENT INSPECTED

State Number: 29884	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: CANTON	Speed: 100
Landings: 4	Installed: 03/01/2016	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
WHITE FURNITURE COMPANY	WHITE FURNITURE COMPANY CAR 2	
201 S CENTER STREET	301 E CENTER STREET	
MEBANE, NC, 27302	MEBANE, NC, 27302	

INSPECTION INFORMATION

Inspection Date 01/29/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE	1
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	---

VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order. Volume is low

Items must be corrected by: 03/30/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Taryn Miller 9197170400

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WHITE FURNITURE COMPANY
201 S CENTER STREET
MEBANE, NC, 27302