



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18031-73-0387**  
State Number  
**17440**

EQUIPMENT INSPECTED

State Number: <b>17440</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 135
Landings: 3	Installed: 01/25/1999	Rope Size: -
Volts: 208	Complied: 01/25/1999	Entrances: 1
OWNER	OCCUPANT	
THE WILLOWS	THE WILLOWS	
124 TARPLEY ST	124 TARPLEY ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 01/31/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6	Replace damaged pickup roller
8.6	Place phone in proper working order

Items must be corrected by: 04/01/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Tamara Walters 3362280597

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE WILLOWS  
124 TARPLEY ST  
BURLINGTON, NC, 27215