



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18033-48-0329
State Number
27360

EQUIPMENT INSPECTED

State Number: 27360	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4500	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 02/17/2011	Rope Size:
Volts: 480	Complied: 02/17/2011	Entrances: 1
OWNER	OCCUPANT	
BRUNSWICK NOVANT MEDICAL CENTER	BRUNSWICK NOVANT MEDICAL CENTER	
240 HOSPITAL DRIVE NE	240 HOSPITAL DRIVE NE	
BOLIVIA, NC, 28422	BOLIVIA, NC, 28422	

INSPECTION INFORMATION

Inspection Date 02/02/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7	Clean the pit and the pit equipment.
2.27.1.1.1	Place the in-car Emergency Phone in working order.

Items must be corrected by: 03/04/2018

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: BEN

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK NOVANT MEDICAL CENTER
240 HOSPITAL DRIVE NE
BOLIVIA, NC, 28422