



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18036-73-3872**  
State Number  
**20282**

#### EQUIPMENT INSPECTED

State Number: <b>20282</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 08/08/2001	Rope Size:
Volts: 480	Complied: 08/09/2001	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE REGIONAL MEDICAL	GENERAL SERVICES	
1230 HUFFMAN MILL RD	3050 GRAND OAKS BLVD	
BURLINGTON, NC, 27320	BURLINGTON, NC, 27320	

#### INSPECTION INFORMATION

Inspection Date 02/05/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

#### VIOLATIONS

2.27.1.1.1	Place the in-car Emergency Phone in working order. Fades in and out
8.6	Replace missing splice tube bolts

Items must be corrected by: 04/06/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jaime TKE 3364620493

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE REGIONAL MEDICAL  
1230 HUFFMAN MILL RD  
BURLINGTON, NC, 27320