



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18038-73-0724
State Number
16068

EQUIPMENT INSPECTED

State Number: 16068	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 09/14/1995	Rope Size:
Volts: 480	Complied: 09/14/1995	Entrances: 1
OWNER	OCCUPANT	
KIRKPATRICK MEDICAL GROUP LLC	KIRKPATRICK MEDICAL GROUP	
1041 KIRKPATRICK RD	1041 KIRKPATRICK RD	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 02/07/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

VIOLATIONS

- 2.14.7.1.2 Place the passenger cab interior lights in working order. 50 lx or 5 fc @ the cab floor.
- 8.6.5.14.1 Provide the annual relief valve and hydraulic system pressure test.
- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.

Items must be corrected by: 04/08/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Troy Pitts 3368145717

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

KIRKPATRICK MEDICAL GROUP LLC
1041 KIRKPATRICK RD
BURLINGTON, NC, 27215