



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18040-75-3755
State Number
22348

EQUIPMENT INSPECTED

State Number: 22348	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: AEC	Speed: 100
Landings: 2	Installed: 04/30/2004	Rope Size: 0
Volts: 208	Complied: 04/30/2004	Entrances: 1
OWNER	OCCUPANT	
ALAN'S PAWN	ALAN'S PAWN	
1186 PATTON AVE.	1186 PATTON AVE.	
ASHEVILLE, NC, 28806	ASHEVILLE, NC, 28806	

INSPECTION INFORMATION

Inspection Date 02/09/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

NCBC Seal Gaps and holes in machine room ceiling (Fire rated.)

Items must be corrected by: 04/10/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Rocky Brown 828-252-8729

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAN'S PAWN
1186 PATTON AVE.
ASHEVILLE, NC, 28806