

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-807-2770

Report Number 18043-73-2154 State Number 29662

EQUIPMENT INSPECTED

State Number: 29662	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 5000	Manuf: TKE	Speed: 135
Landings: 3	Installed: 03/16/2015	Rope Size:
Volts: 208	Complied: 03/16/2015	Entrances: 1
OWNER	OCCUPANT	
HIGHWOODS PROPERTIES	COMPASS POINTE STORAGE CAR 1	
421 FAYETTEVILLE ST.	HWY 119	
WHITSETT, NC, 27601	MEBANE, NC, 27302	

INSPECTION INFORMATION

Inspection Date 02/12/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE	1
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	---

VIOLATIONS

- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.
- 8.6.1.6.5 Provide a class ABC fire extinguisher in the machinery space. Current one has expired inspection

Items must be corrected by: 04/13/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Lori White 9199641800

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372
An invoice will be mailed to:
HIGHWOODS PROPERTIES
421 FAYETTEVILLE ST.
WHITSETT, NC, 27601