



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18044-66-0297
State Number
6817

EQUIPMENT INSPECTED

State Number: 6817	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 1500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 12/22/1970	Rope Size: 0
Volts: 208	Complied: 12/22/1970	Entrances: 1
OWNER	OCCUPANT	
ALEXANDER COUNTY SCHOOLS	ALEXANDER CENTRAL HIGH SCHOOL	
700 LILEDOWN ROAD	241 SCHOOL AVENUE	
TAYLORSVILLE, NC, 28681	TAYLORSVILLE, NC, 28681	

INSPECTION INFORMATION

Inspection Date 02/13/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 66 - Pacitti	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	---------------------------	---------------------

2

VIOLATIONS

NOTE THIS UNIT IS OFF DUE TO STATE VIOLATIONS AND MUST NOT BE TURNED BACK ON UNTIL WITNESSED TESTING

Items must be corrected by: 02/13/2018

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: hgi-stvl.gm@abcinns.com

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALEXANDER COUNTY SCHOOLS
700 LILEDOWN ROAD
TAYLORSVILLE, NC, 28681