



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18044-73-279
State Number
27110

EQUIPMENT INSPECTED

State Number: 27110	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: TKE	Speed: 150
Landings: 2	Installed: 01/15/2010	Rope Size:
Volts: 208	Complied: 01/15/2010	Entrances: 1
OWNER	OCCUPANT	
PROONENT FEDERAL CREDIT UNION	PROONENT FEDERAL CREDIT UNION	
3504 FORESTDALE DRIVE	3504 FORESTDALE DRIVE	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 02/13/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.2.5.1 Place the pit lights in working order. 100 lx or 10 fc @ the pit floor.

Items must be corrected by: 04/14/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Kristina Gutierrez 3365062742

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

PROONENT FEDERAL CREDIT UNION
3504 FORESTDALE DRIVE
BURLINGTON, NC, 27215