



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18046-73-0147
State Number
27508

EQUIPMENT INSPECTED

State Number: 27508	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: KONE	Speed: 150
Landings: 3	Installed: 02/27/2012	Rope Size:
Volts: 208	Complied:	Entrances: 2
OWNER		OCCUPANT
SISSIPAHAW LOFTS CONDOMINIUM ASSOC INC		SAXAPAHAW UPPER MILL
1870 SISSIPAHAW WAY		1616 JORDAN DRIVE
SAXAPAHAW, NC, 27340		SAXAPAHAW, NC, 27340

INSPECTION INFORMATION

Inspection Date 02/15/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.11.1	Provide a monthly test of the Phase 1 and Phase II operation of the firefighters emergency operation.
8.6	Tighten loose handrail in cab
8.6	Perform category 5 testing

Items must be corrected by: 03/17/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Ted Parenti 9199320592

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SISSIPAHAW LOFTS CONDOMINIUM ASSOC INC
1870 SISSIPAHAW WAY
SAXAPAHAW, NC, 27340