



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18046-73-2119
State Number
27172

EQUIPMENT INSPECTED

| | | |
|----------------------------|-------------------------|------------------------|
| State Number: 27172 | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 2500 | Manuf: TKE | Speed: 150 |
| Landings: 3 | Installed: 09/23/2009 | Rope Size: |
| Volts: 460 | Complied: 09/23/2009 | Entrances: 1 |

OWNER

HOSPICE & PALLIATIVE CARE CENTER
918 CHAPEL HILL ROAD
BURLINGTON, NC, 27215

OCCUPANT

HOSPICE & PALLIATIVE CARE CENTER
918 CHAPEL HILL ROAD
BURLINGTON, NC, 27215

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|
| Inspection Date 02/15/2018 | Type Inspection Routine | Certificate Status Re-issued | Inspector 73 - James | County ALAMANCE |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|

1

VIOLATIONS

2.14.7.1.2 Place the passenger cab interior lights in working order. 50 lx or 5 fc @ the cab floor.

Items must be corrected by: 04/16/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Sharon Terrell 3365320122

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

HOSPICE & PALLIATIVE CARE CENTER
918 CHAPEL HILL ROAD
BURLINGTON, NC, 27215