



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18046-73-2590
State Number
17273

EQUIPMENT INSPECTED

State Number: 17273	Type of Unit: Dumbwaiter	Floor to Floor: 1 to 2
Capacity: 500	Manuf: MATOT	Speed: 50
Landings: 2	Installed: 10/31/1997	Rope Size: 3/16
Volts: 208	Complied: 10/31/1997	Entrances: 1
OWNER	OCCUPANT	
FNB BANK	FNB BANK	
708 S CHURCH STREET	708 S CHURCH ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 02/15/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6	Properly install wire rope clips
8.6	Place cab light in working order

Items must be corrected by: 03/17/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Justin Thomas 3365327500

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FNB BANK
708 S CHURCH STREET
BURLINGTON, NC, 27215