N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18051-73-0354
State Number
23204

EQUIPMENT INSPECTED

State Number: **23204**
Capacity: 2500
Landings: 2
Volts: 480

Type of Unit: Passenger
Manuf: OTIS
Installed: 10/18/2005
Complied: 10/18/2005

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
CITY OF MEBANE
106 EAST WASHINGTON ST
MEBANE, NC, 27302

OCCUPANT
MEBANE PUBLIC LIBRARY
2ND & WASHINGTON ST
MEBANE, NC, 27302

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
02/20/2018	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Kathryn Arends 9195635308 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CITY OF MEBANE
106 EAST WASHINGTON ST
MEBANE, NC, 27302