



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18051-73-1123
State Number
20645

EQUIPMENT INSPECTED

State Number: 20645	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 135
Landings: 2	Installed: 02/25/2003	Rope Size: 0
Volts: 480	Complied: 02/25/2003	Entrances: 1
OWNER	OCCUPANT	
GRAHAM/MEBANE WATER PLANT	GRAHAM/MEBANE WATER PLANT	
P.O. DRAWER 357	1824 HWY 70	
GRAHAM, NC, 27253	MEBANE, NC, 27302	

INSPECTION INFORMATION

Inspection Date 02/20/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.7 Clean the pit and the pit equipment.

Items must be corrected by: 04/21/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jimmy Aiken 3363783264

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

GRAHAM/MEBANE WATER PLANT
P.O. DRAWER 357
GRAHAM, NC, 27253