N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18057-66-041
State Number
21159

EQUIPMENT INSPECTED

State Number: **21159**
Capacity: 4500
Landings: 2
Volts: 480

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 11/17/2003
Complied: 11/17/2003

Floor to Floor: 1 to 2
Speed: 125
Rope Size: 0
Entrances: 1

OWNER
N.C. DEPARTMENT OF CORRECTIONS
831 WEST MORGAN STREET
RALEIGH, NC, 27603

OCCUPANT
ALEXANDER CORRECTIONAL
633 OLD LANDFILL RD
TAYLORSVILLE, NC, 28681

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
02/26/2018	Routine	Re-issued	66 - Pacitti	ALEXANDER

2

VIOLATIONS

8.6.4.7 Clean the pit and the pit equipment.

Items must be corrected by: 04/27/2018

Elevator Name: # J

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: allen.huffman@ncdps.gov

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
N.C. DEPARTMENT OF CORRECTIONS
831 WEST MORGAN STREET
RALEIGH, NC, 27603