



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18057-66-4298**  
State Number  
**4098**

EQUIPMENT INSPECTED

State Number: <b>4098</b>	Type of Unit: Freight	Floor to Floor: B to 2
Capacity: 4000	Manuf: PARK	Speed: 50
Landings: 3	Installed: 06/29/1959	Rope Size: 0
Volts: 550	Complied: 03/10/1997	Entrances: 2
OWNER	OCCUPANT	
SCHNEIDER MILLS	SCHNEIDER MILLS	
P.O. BOX 519	1170 HWY16 NORTH	
TAYLORSVILLE, NC, 28681	TAYLORSVILLE, NC, 28681	

INSPECTION INFORMATION

Inspection Date 02/26/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 66 - Pacitti	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	---------------------------	---------------------

2

VIOLATIONS

6.1.6.9.3	Additional signs or graphics on the elevator not for passengers do not ride material only do not ride
2.11.11.5	Replace the damaged hoistway doors.at 2nd floor [ door guides ]
5.1.21.1	Place the car alarm bell in working order. Minimum level of 80 dBA.
2.14.4.7	Replace the damaged car gate.sheave cable guides in rail

Items must be corrected by: 03/28/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: RUFUS W. 828-632-8181

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SCHNEIDER MILLS  
P.O. BOX 519  
TAYLORSVILLE, NC, 28681