



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18057-66-5049
State Number
21160

EQUIPMENT INSPECTED

State Number: 21160	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 11/17/2003	Rope Size: 0
Volts: 480	Complied: 11/17/2003	Entrances: 1
OWNER	OCCUPANT	
N.C. DEPARTMENT OF CORRECTIONS	ALEXANDER CORRECTIONAL	
831 WEST MORGAN STREET	633 OLD LANDFILL ROAD	
RALEIGH, NC, 27603	TAYLORSVILLE, NC, 28681	

INSPECTION INFORMATION

Inspection Date 02/26/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 66 - Pacitti	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	---------------------------	---------------------

2

VIOLATIONS

2.27.1.1.6	Place intercom operability verification means in working order.
8.6.4.7	Remove oil from the pit floor

Items must be corrected by: 04/27/2018

Elevator Name: # L

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: allen.huffman@ncdps.gov

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

N.C. DEPARTMENT OF CORRECTIONS
831 WEST MORGAN STREET
RALEIGH, NC, 27603