



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18060-48-413
State Number
14327

EQUIPMENT INSPECTED

State Number: 14327	Type of Unit: Passenger	Floor to Floor: G to 2
Capacity: 3000	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 05/20/1991	Rope Size:
Volts: 208	Complied: 05/22/1991	Entrances: 1
OWNER	OCCUPANT	
OCEAN ISLE INN	OCEAN ISLE INN	
37 W FIRST ST	37 W FIRST ST	
OCEAN ISLE BEACH, NC, 28469	OCEAN ISLE BEACH, NC, 28469	

INSPECTION INFORMATION

Inspection Date 03/01/2018	Type Inspection Alteration	Certificate Status Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	-------------------------------	------------------------------	--------------------------	---------------------

10

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SCOTT [SCHINDLER]

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN ISLE INN
37 W FIRST ST
OCEAN ISLE BEACH, NC, 28469