



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18065-48-158**  
State Number  
**17013**

EQUIPMENT INSPECTED

State Number: <b>17013</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 150
Landings: 4	Installed: 11/24/1997	Rope Size:
Volts: 480	Complied: 01/09/1998	Entrances: 1
OWNER	OCCUPANT	
BENCHMARK MANAGEMENT	WINDJAMMER CONDO	
C/O JANE WHIELDON	27 W 2ND ST	
NORTH MYRTLE BEACH, SC, 29597	OCEAN ISLE, NC, 28469	

INSPECTION INFORMATION

Inspection Date 03/06/2018	Type Inspection Compliance	Certificate Status Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	-------------------------------	------------------------------	--------------------------	---------------------

10

VIOLATIONS

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Chuck [TKE]

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BENCHMARK MANAGEMENT  
C/O JANE WHIELDON  
NORTH MYRTLE BEACH, SC, 29597