



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18068-48-4137
State Number
12252

EQUIPMENT INSPECTED

State Number: 12252	Type of Unit: Passenger	Floor to Floor: 1 to -
Capacity: 4000	Manuf: SOUTHERN	Speed: 100
Landings: 5	Installed: 11/03/1987	Rope Size: 5/8
Volts: 480	Complied: 06/12/2006	Entrances: 1
OWNER	OCCUPANT	
CAPITAL POWER CORP	CAPITAL POWER CORP.	
1281 POWERHOUSE DR	1281 POWERHOUSE DR.	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 03/09/2018	Type Inspection Alteration	Certificate Status Limited	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	-------------------------------	-------------------------------	--------------------------	---------------------

10

VIOLATIONS

N/A LIMITED CERTIFICATE ISSUED DUE TO FIRE RECALL ANNUNCIATOR.

Items must be corrected by: 06/09/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MIKE [SOUTHERN]

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAPITAL POWER CORP
1281 POWERHOUSE DR
SOUTHPORT, NC, 28461