



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18082-76-2673
State Number
15672

EQUIPMENT INSPECTED

State Number: 15672	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: KONE	Speed: 80
Landings: 2	Installed: 09/26/1994	Rope Size:
Volts: 480	Complied: 09/28/1994	Entrances: 1
OWNER	OCCUPANT	
BOTTOMLEYS EVERGREEN FARM	BOTTOMLEYS EVERGREEN FARM	
5071 GLADE VALLEY RD.	114 INDUSTRIAL PARK DR.	
ENNICE, NC, 28623	SPARTA, NC, 28675	

INSPECTION INFORMATION

Inspection Date 03/23/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ALLEGHANY
-------------------------------	----------------------------	---------------------------------	-------------------------	---------------------

3

VIOLATIONS

2.7.9.1 Place the machine room or space lights in working order. Flourscent tubes need to be protected

Items must be corrected by: 05/22/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Bottomleys Farm 336-657-1705

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BOTTOMLEYS EVERGREEN FARM
5071 GLADE VALLEY RD.
ENNICE, NC, 28623