



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18086-72-2496
State Number
5938

EQUIPMENT INSPECTED

| | | |
|---------------------------|--------------------------|------------------------|
| State Number: 5938 | Type of Unit: Passenger | Floor to Floor: 1 to 6 |
| Capacity: 2000 | Manuf: SCHINDLER | Speed: 300 |
| Landings: 6 | Installed: 03/27/1968 | Rope Size: 1/2 |
| Volts: 208 | Complied: 04/08/1968 | Entrances: 1 |
| OWNER | OCCUPANT | |
| FIRST EMPIRE TELEX | FIRST RALEIGH TELEX BLDG | |
| C/O EMPIRE PROPERTIES | 234 FAYETTEVILLE ST | |
| RALEIGH, NC, 27601 | RALEIGH, NC, 27601 | |

INSPECTION INFORMATION

| | | | | | |
|-------------------------------|----------------------------|---------------------------------|---------------------------|----------------|------|
| Inspection Date 03/27/2018 | Type Inspection Routine | Certificate Status Re-issued | Inspector 72 - Mccloud | County WAKE | 92 D |
|-------------------------------|----------------------------|---------------------------------|---------------------------|----------------|------|

VIOLATIONS

| | |
|----------------|---|
| 8.6.4.9 | Clean the oil from the car top. |
| 2.26.11 | Take steps to provide proper floor level accuracy at top landing. |
| 8.6.8.9 | Signs. Firefighter operation signs shall be provided. |
| 8.6.1.7.2 | Provide the appropriate test tag. |
| 8.6.4.19.2 (b) | Provide the annual no load test. |

Items must be corrected by: 05/26/2018

Elevator Name: ELEVATOR #2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: na

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIRST EMPIRE TELEX
C/O EMPIRE PROPERTIES
RALEIGH, NC, 27601