



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18093-48-0637**  
State Number  
**23468**

### EQUIPMENT INSPECTED

State Number: <b>23468</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 55
Landings: 3	Installed: 08/04/2005	Rope Size:
Volts: 240	Complied: 09/08/2005	Entrances: 1
OWNER	OCCUPANT	
THE WOODLANDS @ CROW CREEK	CROW CREEK BLDG #5	
10255 BEACH DR SW	270 WOODLANDS WAY	
CALABASH, NC, 28467	CALABASH, NC, 28467	

### INSPECTION INFORMATION

Inspection Date 04/03/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

### VIOLATIONS

8.6.5.5.2	Empty the drain bucket in the pit.
2.7.3.4.1	Provide a self closing self-locking machine room / space door.
2.7.9.1	Place the machine room or space lights in working order. 200 lx or 19 fc @ the machine room floor.
5.1.21.1	Place the car alarm bell in working order. Minimum level of 80 dBA.
8.6.4.19.2 (b)	Provide the annual no load test.

Items must be corrected by: 05/03/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE WOODLANDS @ CROW CREEK  
10255 BEACH DR SW  
CALABASH, NC, 28467