



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18093-48-1324
State Number
22316

EQUIPMENT INSPECTED

State Number: 22316	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 65
Landings: 3	Installed: 10/20/2004	Rope Size:
Volts: 240	Complied: 11/04/2004	Entrances: 1
OWNER THE WOODLANDS @ CROW CREEK 10255 BEACH DR SW CALABASH, NC, 28467		OCCUPANT CROW CREEK CONDOS #3 290 WOODLANDS WAY, SW CALABASH, NC, 28467

INSPECTION INFORMATION

Inspection Date 04/03/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7	Clean the pit and the pit equipment.
5.1.21.1	Place the car alarm bell in working order. Minimum level of 80 dBA.
8.6.4.19.2 (b)	Provide the annual no load test.

Items must be corrected by: 05/03/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE WOODLANDS @ CROW CREEK
10255 BEACH DR SW
CALABASH, NC, 28467