



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18096-48-2757
State Number
24566

EQUIPMENT INSPECTED

State Number: 24566	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 55
Landings: 3	Installed: 02/21/2007	Rope Size: 0
Volts: 230	Complied:	Entrances: 1
OWNER THE WOODLANDS @ CROW CREEK 10255 BEACH DR SW CALABASH, NC, 28467		OCCUPANT CROW CREEK - BLDG #13 395 S CROW CREEK DRIVE CALABASH, NC, 28467

INSPECTION INFORMATION

Inspection Date 04/06/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.1	Place the in-car Emergency Phone in working order.
8.6.4.8	Clean the machine room and the machine room equipment.
2.7.9.1	Place the machine room or space lights in working order. 200 lx or 19 fc @ the machine room floor.
2.7.3.4.1	Provide a self closing self-locking machine room / space door.

Items must be corrected by: 05/06/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE WOODLANDS @ CROW CREEK
10255 BEACH DR SW
CALABASH, NC, 28467