N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18096-48-4936
State Number
24648

EQUIPMENT INSPECTED

State Number: **24648**
Capacity: 2000
Landings: 3
Volts: 230

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 02/01/2007
Complied:

Floor to Floor: 1 to 3
Speed: 55
Rope Size: 0
Entrances: 1

OWNER
CROW CREEK BLDG #11
395 SOUTH CROW CREEK DRIVE
CALABASH, NC, 28467

OCCUPANT
CROW CREEK - BLDG #11
395 SOUTH CROW CREEK DRIVE
CALABASH, NC, 28467

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
04/06/2018	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

8.6.4.7	Clean the pit and the pit equipment.
2.7.9.1	Place the machine room or space lights in working order. 200 lx or 19 fc @ the machine room floor.
N/A	RE-CONNECT PIPE IN MOTOR ROOM

Items must be corrected by: 05/06/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CROW CREEK BLDG #11
395 SOUTH CROW CREEK DRIVE
CALABASH, NC, 28467