



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18099-79-0171
State Number
9865

EQUIPMENT INSPECTED

State Number: 9865	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: SOUTHERN	Speed: 125
Landings: 4	Installed: 08/17/1981	Rope Size: 0
Volts: 208	Complied: 05/12/2003	Entrances: 1
OWNER	OCCUPANT	
WASHINGTON HOUSING AUTHORITY	EAST HAVEN	
PO BOX 1046	407 E. THIRD STREET	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 04/09/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 79 - Cumberland	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	------------------------------	--------------------

7

VIOLATIONS

8.6.4.13.1(i)	Place the door restrictor in proper working order.
8.6.4.7	Clean the pit and the pit equipment. (second notice)

Items must be corrected by: 06/08/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: main office

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WASHINGTON HOUSING AUTHORITY
PO BOX 1046
WASHINGTON, NC, 27889