



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18099-79-2946**  
State Number  
**30374**

EQUIPMENT INSPECTED

State Number: <b>30374</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 1400	Manuf: SAVARIA	Speed: 30
Landings: 2	Installed: 02/17/2016	Rope Size: 3/8
Volts: 230	Complied:	Entrances: 1
OWNER	OCCUPANT	
FIRST UNITED METHODIST CHURCH	FIRST UNITED METHODIST CHURCH	
304 W 2ND STREET	304 W 2ND STREET	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 04/09/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 79 - Cumberland	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	------------------------------	--------------------

7

VIOLATIONS

8.6.4.7	Remove oil from the pit floor ( channel )
8.6.5.14.1	Provide the annual relief valve and hydraulic system pressure test.

Items must be corrected by: 06/08/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: main office

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIRST UNITED METHODIST CHURCH  
304 W 2ND STREET  
WASHINGTON, NC, 27889