



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18106-73-559**  
State Number  
**1037**

EQUIPMENT INSPECTED

State Number: <b>1037</b>	Type of Unit: Freight	Floor to Floor: B to 1
Capacity: 3000	Manuf: WESTBROOK	Speed: 60
Landings: 2	Installed: 02/17/1948	Rope Size: 1/2
Volts: 220	Complied: 04/04/1991	Entrances: 2
OWNER	OCCUPANT	
GRAHAM DYEING & FINISHING	GRAHAM DYEING & FINISHING	
110 N BROAD ST	110 N BROAD ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 04/16/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

- 8.6.3.4 Replace the governor rope.
- 2.2.5.1 Place the freight cab interior lights in working order. 25 lx or 2.5 fc @ the cab floor.
- 2.7.9.1 Place the machine room or space lights in working order. 200 lx or 19 fc @ the machine room floor.

Items must be corrected by: 06/15/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Victoria Peat 3362289981

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

GRAHAM DYEING & FINISHING  
110 N BROAD ST  
BURLINGTON, NC, 27215