



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18108-76-041**  
State Number  
**10465**

EQUIPMENT INSPECTED

State Number: <b>10465</b>	Type of Unit: Passenger	Floor to Floor: L to 11
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 350
Landings: 11	Installed: 10/07/1983	Rope Size: 1/2
Volts: 208	Complied: 10/04/2006	Entrances: 1
OWNER	OCCUPANT	
SUGAR TOP HOMEOWNERS	SUGAR TOP RESORT	
303 SUGAR TOP DRIVE	303 SUGAR TOP DRIVE	
BANNER ELK, NC, 28604	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 04/18/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County AVERY
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

6

VIOLATIONS

- 8.6.4.9 Clean the car top.
- 2.11.11.5 Replace the damaged car door. Door rubbing ca panel
- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.

Items must be corrected by: 06/17/2018

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Shad 828-898-5226

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SUGAR TOP HOMEOWNERS  
303 SUGAR TOP DRIVE  
BANNER ELK, NC, 28604