



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18108-76-1576**  
State Number  
**11158**

#### EQUIPMENT INSPECTED

State Number: <b>11158</b>	Type of Unit: Passenger	Floor to Floor: L to 10
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 350
Landings: 11	Installed: 09/10/1985	Rope Size: 5/8
Volts: 208	Complied: 03/24/2006	Entrances: 1

OWNER  
SUGAR TOP HOMEOWNERS  
303 SUGAR TOP DRIVE  
BANNER ELK, NC, 28604

OCCUPANT  
SUGAR TOP RESORT  
303 SUGAR TOP DRIVE  
BANNER ELK, NC, 28604

#### INSPECTION INFORMATION

Inspection Date 04/18/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County AVERY
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

6

#### VIOLATIONS

- 5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA. Needs to work with power off
- 2.14.7.1.3 Place the in-car emergency lights in working order. The auxillary lighting illumination shall not be less than 2 lx (0.2 fc) measured at any point between 48 in. and 35 in. above the car floor and approximately 12 in. centered horizontally in front o

Items must be corrected by: 06/17/2018

Elevator Name: # 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Shad 828-898-5226

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SUGAR TOP HOMEOWNERS  
303 SUGAR TOP DRIVE  
BANNER ELK, NC, 28604