



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18108-76-1686
State Number
10466

EQUIPMENT INSPECTED

State Number: 10466	Type of Unit: Passenger	Floor to Floor: L to 10
Capacity: 2500	Manuf: THYSEN KRUPP	Speed: 350
Landings: 11	Installed: 09/27/1983	Rope Size: 1/2
Volts: 208	Complied: 10/07/1983	Entrances: 1

OWNER
SUGAR TOP HOMEOWNERS
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604

OCCUPANT
SUGAR TOP RESORT
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604

INSPECTION INFORMATION

Inspection Date 04/18/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County AVERY
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

6

VIOLATIONS

- | | |
|-------------------|--|
| 8.6.4.8.2 | Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms. Remove used fluorescent tubes and old fixture |
| 2.14.1.5.1
(f) | Place the Top of Car emergency exit switch in working order. |
| 8.6.4.9 | Clean the car top. |

Items must be corrected by: 06/17/2018

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Shad 828-898-5226

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SUGAR TOP HOMEOWNERS
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604