NCDOL NCDOL N. Department of labor

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 18113-48-5299 State Number 23484

		EQUIPMENT INSPECTED		
State Number: 23484 Type of Unit: Pass		senger Floor to Floor: 1 to 4		or: 1 to 4
Capacity: 3000	Capacity: 3000 Manuf: THYSSEN KRUPP Landings: 4 Installed: 11/04/2005		Speed: 125 Rope Size: Entrances: 1	
Landings: 4				
Volts: 208				
OWNER		OCCUPANT		
CAM	ISLANDER RESORT - BLDG. #31 161 VIA OLD SOUND BLVD			
P.O. BOX 8126				
OCEAN ISLE BEACH, NC, 28469 OCEAN ISLE BEACH, NC, 28469				
	 P	NSPECTION INFORMATION		
Inspection Date 04/23/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
		VIOLATIONS		
8.6.4.19.2 (b)	Provide the annua	al no load test.		
Items must be corrected by: 05	/23/2018			
Notify the Elevator Bureau in writi complainace with current codes.	ng on Corrected Violations Form	when the following corrections	have been made in order to	bring your equipment into
Violations pointed out to: UNAVA		Inspector		
To make changes to the invoice mailing address please call: 919-733-0372 THIS IS NOT AN INVOICE An invoice will be mailed to: P.O. BOX 8126				