



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18115-65-3130
State Number
25778

EQUIPMENT INSPECTED

State Number: 25778	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4500	Manuf: TKE	Speed: 125
Landings: 3	Installed: 03/28/2008	Rope Size:
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
10 BROOK STREET LLC	10 BROOK STREET	
10 BROOK ST STE 205	10 BROOK STREET	
ASHEVILLE, NC, 28803	ASHEVILLE, NC, 28803	

INSPECTION INFORMATION

Inspection Date 04/25/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------	------

VIOLATIONS

- 8.6.1.6.5 Provide a NBCC Class ABC fire extinguisher convenient to the access door in the machine room / space. 2nd notice
- 8.6.4.7 Remove the water from the pit floor and take steps to prevent its re-entry. 2nd notice
- 2.2.5.1 Place the pit lights in working order. 100 lx or 10 fc @ the pit floor. 2nd notice

Items must be corrected by: 05/05/2018

Elevator Name: A

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Brian Keefer 828-575-7061

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
10 BROOK STREET LLC
10 BROOK ST STE 205
ASHEVILLE, NC, 28803