



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18116-76-1677
State Number
H2825

EQUIPMENT INSPECTED

| | | |
|----------------------------|-------------------------|------------------------|
| State Number: H2825 | Type of Unit: Hand Lift | Floor to Floor: 1 to 2 |
| Capacity: 750 | Manuf: GARAVENTA | Speed: 30 |
| Landings: 2 | Installed: 12/14/2016 | Rope Size: |
| Volts: 230 | Complied: | Entrances: 1 |
| OWNER | OCCUPANT | |
| VISTAS @ BANNER ELK | VISTAS AT BANNER ELK #8 | |
| 319 PENNY LANE | 494 PENNY LANE | |
| BANNER ELK, NC, 28604 | BANNER ELK, NC, 28604 | |

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|-----------------|
| Inspection Date 04/26/2018 | Type Inspection Routine | Certificate Status Re-issued | Inspector 76 - Crank | County AVERY |
|-------------------------------|----------------------------|---------------------------------|-------------------------|-----------------|

6

VIOLATIONS

8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.

Items must be corrected by: 06/25/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JP 828-964-245

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

VISTAS @ BANNER ELK
319 PENNY LANE
BANNER ELK, NC, 28604