



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18116-76-3715
State Number
H2510

EQUIPMENT INSPECTED

State Number: H2510	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: GARAVENTA	Speed: 30
Landings: 2	Installed: 12/19/2013	Rope Size: 3/8
Volts: 230	Complied: 12/19/2013	Entrances: 2
OWNER	OCCUPANT	
BANNER ELK VISTA PROPERTIES	VISTAS @ BANNER ELK #6	
PO BOX 2486	410 PENNY LANE	
BANNER ELK, NC, 28604	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 04/26/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County AVERY
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

6

VIOLATIONS

8.6.4.8	Remove the water from the machine room floor.
2.7.3.4.1	Provide a self closing self-locking machine room / space door.

Items must be corrected by: 06/25/2018

Elevator Name: # 6

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JP 828-964-2458

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BANNER ELK VISTA PROPERTIES
PO BOX 2486
BANNER ELK, NC, 28604