



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18116-76-5557**  
State Number  
**H2509**

EQUIPMENT INSPECTED

State Number: <b>H2509</b>	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: GARAVENTA	Speed: 30
Landings: 2	Installed: 12/11/2013	Rope Size: 3/8
Volts: 230	Complied: 12/11/2013	Entrances: 2
OWNER BANNER ELK VISTA PROPERTIES PO BOX 2486 BANNER ELK, NC, 28604	OCCUPANT VISTAS @ BANNER ELK #5 325 PENNY LANE BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 04/26/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County AVERY
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

6

VIOLATIONS

- 8.6.4.13.1 (k) Take steps to make the hoistway doors self-closing and self-locking. Doors intermittently not working
- 2.7.3.4.1 Provide a self closing self-locking machine room / space door. Door needs adjusting
- 2.7.9.1 Place the machine room or space lights in working order. 200 lx or 19 fc @ the machine room floor.
- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.

Items must be corrected by: 06/25/2018

Elevator Name: # 5

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JP 828-964-2458

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BANNER ELK VISTA PROPERTIES  
PO BOX 2486  
BANNER ELK, NC, 28604