



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18128-73-3872**  
State Number  
**16902**

#### EQUIPMENT INSPECTED

State Number: **16902**

Capacity: 4000

Landings: 4

Volts: 208

Type of Unit: Passenger

Manuf: SCHINDLER

Installed: 01/17/1997

Complied: 01/17/1997

Floor to Floor: B to 3

Speed: 150

Rope Size:

Entrances: 1

OWNER

LAB CORP

348 S MAIN ST

BURLINGTON, NC, 27215

OCCUPANT

LAB CORP "CAMMACK BDLG"

133 E DAVIS ST

BURLINGTON, NC, 27215

#### INSPECTION INFORMATION

Inspection Date  
05/08/2018

Type Inspection  
Compliance

Certificate Status  
Not Issued

Inspector  
73 - James

County  
ALAMANCE

1

#### VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 07/07/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Patrick Schindler elevator

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LAB CORP  
348 S MAIN ST  
BURLINGTON, NC, 27215