



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18128-73-5158
State Number
21192

EQUIPMENT INSPECTED

State Number: 21192	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 09/10/2002	Rope Size: 0
Volts: 208	Complied: 09/10/2002	Entrances: 1
OWNER	OCCUPANT	
HOLIDAY INN EXPRESS	HOLIDAY INN EXPRESS	
149 SPRING FOREST DRIVE	149 SPRING FOREST DRIVE	
MEBANE, NC, 27302	MEBANE, NC, 27302	

INSPECTION INFORMATION

Inspection Date 05/08/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.
- 2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 07/07/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Lesia Dziurma 9193049900

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

HOLIDAY INN EXPRESS
149 SPRING FOREST DRIVE
MEBANE, NC, 27302