



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18129-73-0715**  
State Number  
**26097**

#### EQUIPMENT INSPECTED

State Number: <b>26097</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: SCHINDLER	Speed: 100
Landings: 3	Installed: 05/13/2008	Rope Size:
Volts: 208	Complied: 05/13/2008	Entrances: 1

#### OWNER

ETHAN POINTE APARTMENTS  
2978 ETHAN POINTE DRIVE  
BURLINGTON, NC, 27215

#### OCCUPANT

ETHAN POINTE APARTMENTS  
1176 KIRKPATRICK RD  
BURLINGTON, NC, 27215

#### INSPECTION INFORMATION

Inspection Date 05/09/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

#### VIOLATIONS

8.6.1.6.5 Provide a class ABC fire extinguisher in the machinery space. Current inspection expired

Items must be corrected by: 07/08/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Karen Bacon 3365843337

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ETHAN POINTE APARTMENTS  
2978 ETHAN POINTE DRIVE  
BURLINGTON, NC, 27215