



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18129-73-2154
State Number
25401

EQUIPMENT INSPECTED

State Number: 25401	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: SCHINDLER	Speed: 100
Landings: 3	Installed: 02/07/2007	Rope Size: 0
Volts: 208	Complied: 02/07/2007	Entrances: 1
OWNER	OCCUPANT	
ETHAN POINTE LLC	ETHAN POINTE APARTMENTS	
905 ARBORETUM DR	1176 KIRKPATRICK ROAD	
WILMINGTON, NC, 28403	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 05/09/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.7	Clean the pit and the pit equipment.
8.6	Place currenty inspected fire exstinguisher in machine room
8.6	Patch hole in hoistway wall

Items must be corrected by: 07/08/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Karen Bacon3365843337

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ETHAN POINTE LLC
905 ARBORETUM DR
WILMINGTON, NC, 28403