N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18129-73-5418
State Number
25483

EQUIPMENT INSPECTED

State Number: **25483**
Capacity: 2500
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: SCHINDLER
Installed: 02/07/2008
Complied: 02/07/2008

Floor to Floor: 1 to 3
Speed: 100
Rope Size: 0
Entrances: 1

OWNER
ETHAN POINTE APARTMENTS
2978 ETHAN POINTE DRIVE
BURLINGTON, NC, 27215

OCCUPANT
ETHAN POINTE APARTMENTS
1176 KIRKPATRICK ROAD
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
05/09/2018	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

8.6.4.7 Clean the pit and the pit equipment.
8.6.1.6.5 Provide a class ABC fire extinguisher in the machinery space. Current inspection expired

Items must be corrected by: 07/08/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Karen Bacon 3365843337 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ETHAN POINTE APARTMENTS
2978 ETHAN POINTE DRIVE
BURLINGTON, NC, 27215