



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18141-79-0411
State Number
N7.2

EQUIPMENT INSPECTED

State Number: N7.2	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 1500	Manuf: WESTBROOK	Speed: 100
Landings: 3	Installed: 05/27/1975	Rope Size: 5/8
Volts: 220	Complied: 05/27/1975	Entrances: 1
OWNER	OCCUPANT	
GW WALKER & SONS	GW WALKER & SONS	
203 W MAIN ST	203 W MAIN ST	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 05/21/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 79 - Cumberland	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	------------------------------	--------------------

7

VIOLATIONS

A 17.6 - 1.10.2	(deadends on drum side to be refasten yearly)
2.16.3.1	Provide a capacity plate inside the car. The capacity plate shall be in a conspicuous location inside the car.
8.6.1.7.2	Provide the appropriate test tag.(make tag ledgeable)
8.6.4.19.2 (b)	Provide the annual no load test.

Items must be corrected by: 07/20/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: main office

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

GW WALKER & SONS
203 W MAIN ST
WASHINGTON, NC, 27889