



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18142-73-4027**  
State Number  
**13884**

EQUIPMENT INSPECTED

State Number: <b>13884</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 01/15/1991	Rope Size:
Volts: 208	Complied: 01/15/1991	Entrances: 1
OWNER	OCCUPANT	
ANDERSEN ENERGY, INC.	ANDERSEN PRODUCTS, INC.	
3151 CAROLINE DR.	3202 CAROLINE DR.	
HAW RIVER, NC, 27258	HAW RIVER, NC, 27258	

INSPECTION INFORMATION

Inspection Date 05/22/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.
- 8.6.5.14.1 Provide the annual relief valve and hydraulic system pressure test.
- 8.6 Place in case of fire sign at each landing

Items must be corrected by: 07/21/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Ethan Marshall 3363763000

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ANDERSEN ENERGY, INC.  
3151 CAROLINE DR.  
HAW RIVER, NC, 27258