



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18142-73-5313
State Number
11988

EQUIPMENT INSPECTED

State Number: 11988	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 11/12/1986	Rope Size:
Volts: 208	Complied: 12/08/1986	Entrances: 1
OWNER	OCCUPANT	
TAR HEEL DRUG COMPANY	TAR HEEL DRUG COMPANY	
316 S MAIN ST	316 S MAIN ST	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 05/22/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.2.2.6	Provide a sump pump cover, the cover shall be secure and level with the floor.
8.6.4.7	Remove the water from the pit floor and take steps to prevent its re-entry.
8.6.4.9	Clean the car top.
8.6.1.6.5	Provide a class ABC fire extinguisher in the machinery space. Current one expired in 2016
8.6	Provide in case of fire sign at each landing
8.6	Provide catch bucket in pit for oil leakage

Items must be corrected by: 07/21/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Moizzam Shaikh 3362272093

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

TAR HEEL DRUG COMPANY
316 S MAIN ST
GRAHAM, NC, 27253